

January 25, 2016

TO: All Bidders

RE: Informal Bid 2016-03 Addendum # 1

ADDENDUM NO. 1

This **ADDENDUM #1** forms part of Moore County's Informal Bid for Flow Monitoring Station – Taylortown – Lincoln Avenue for the County of Moore. All requirements of the original specifications remain in effect in their respective order. **Receipt of this Addendum must be acknowledged by its inclusion with the Informal Bid and noted as an inclusion on the sealed envelope.**

The following changes and/or clarifications are hereby made to the original Informal Bid:

Sealed bids are due at 4:00 PM Tuesday February 2, 2016.

Questions will be accepted until 10:00 am Wednesday January 27, 2016 to tvuncannon@moorecountync.gov.

1. Question: Who is responsible for Bypass Pumping?
Answer: Moore County Public Works will perform the Bypass Pumping in coordination with Taylortown. There should be no cost by Contractor in the project for Bypass Pumping.
2. Question: Where will the meter base be installed?
Answer: The meter base installation will be revised from being installed on the pole that will be installed by Duke Power to the back side of the proposed Panel. A copy of the revised Sheet E-1 is included, noting this change.
3. Question: We request approval to quote a Rosemount Emerson 8750WD Magnetic Flow Meter. Rosemount is a well-respected manufacturer of magmeters and other process instrumentation. I have attached information for your review. You need to be sure that the magmeter has a contact closure output for flow total to send to the Aquavx unit. That is an option on most meters
Answer: Rosemont Emerson 8750WD Flow Meter is accepted as approved materials for use on this project.
4. Question: We request approval to quote Tracom on the FRP Magmeter Manhole. Tracom has manufactured custom metering manholes for nearly 30 years and has become an industry standard. I have attached a brochure on their Packaged Metering Manholes and will send more information later today or Monday.
Answer: Tracom FRP Manhole enclosure is accepted as approved materials for use on this project.
5. Question: Can you provide a list of the contractors who may be bidding this project?
Answer: The following firms were sent the bid packet or have requested information.
Atkinson Infrastructures
Sanford Contractors
Columbus Utilities Inc.
Sandhills Contractors Inc.
Wellons Construction

Thomas Construction Company
Nall Contractors LLC
Charles R. Underwood
ELJ Inc.
A.C. Schultes
Clearwater Inc.
MidEast Railroad

Proposals are due to Terra Vuncannon at 206 South Ray Street Carthage NC 28327 by 4:00 pm
February 2, 2016.

END OF ADDENDUM NO. 1

Sincerely,

Terra Vuncannon
Purchasing Manager
County of Moore